

# AENOR

## Certificate of constancy of performance

CE  
0099

0099/CPR/A74/0082

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

### COFEM, S.A.

registered office	CR MOLINS DE REI A RUBI, Km. 8,4 08191 RUBI (Barcelona - España)
Construction Product	Power supply equipment
Harmonised Standard	EN 54-4:1997 EN 54-4:1997/AC:1999 EN 54-4:1997/A1:2002 EN 54-4:1997/A2:2006
References	Specified in Annex to the Certificate
Production site	CR MOLINS DE REI A RUBI, Km. 8,4 08191 RUBI (Barcelona - España)
Certification scheme	This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonised standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on	2009-11-11
Last issued on	2020-11-11
Validity date	2021-11-11



Rafael GARCÍA MEIRO  
Chief Executive Officer

Original Electronic Certificate

# AENOR

## Certificate of constancy of performance

0099/CPR/A74/0082

### Annex to Certificate

Trade Mark	Model/reference	Supply voltage	Frecuency	Output voltage/current	Output	Electric safety class
COFEM	CDFA-03	230 VAC	50 Hz	29,7 VDC	65 W	CLASE I

Original Electronic Certificate

First issued on 2009-11-11  
Last issued on 2020-11-11  
Validity date 2021-11-11

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- www.aenor.com

Control body accredited by ENAC. Accreditation number: 1/C-PR356