



Certificate of constancy of performance

0099/CPR/A74/0101

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

COFEM, S.A.

registered office CL COMPOSITOR WAGNER, 8 - PI CAN JARDÍ 08191 RUBÍ (Barcelona - España)

Construction Product **Power supply equipment**

Harmonised Standard EN 54-4:1997
EN 54-4:1997/AC:1999
EN 54-4:1997/A1:2002
EN 54-4:1997/A2:2006

References Specified in Annex to the Certificate

Production site CL COMPOSITOR WAGNER, 8 - PI CAN JARDÍ 08191 RUBÍ (Barcelona - España)

Certification scheme This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonised standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2010-03-15
Last issued on 2025-03-09
Validity 2026-03-09

Rafael GARCÍA MEIRO
CEO



AENOR CONFÍA S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com



Certificate of constancy of performance

0099/CPR/A74/0101

Annex to Certificate

Trade Mark	Model/reference	Supply voltage	Frecuency	Output voltage/current	Output	Electric safety class
COFEM	CDFA-02	230 VAC	50 - 60 Hz	27 VDC	65 W	CLASE I

First issued on 2010-03-15
Last issued on 2025-03-09
Validity 2026-03-09



AENOR CONFÍA S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com